

Classification Report

Number	19-001962-PR02 (NW-A01-0203-en-02)
Owner	Metaloumin SA 20 Aghiou Fanouriou Str. 136 71 Acharnes - Athens Greece
Product	Lift-sliding door, scheme D
Designation	Shipping name: Energy 45
Details	Manufacturer Metaloumin SA, - Acharnes - Athens; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction Sash left before sash right; Overall dimensions (W x H) 1400 mm x 2200 mm
Special features	Test sequence. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage.

Result

Operating forces according to EN 13115:2001-07

**Class: 1**

Air permeability according to EN 12207:2016-12

**Class: 3**

Resistance to wind load according to EN 12210:2016-03

**Class: C3/B3**

Watertightness according to EN 12208:1999-11

**Class: 3A**ift Rosenheim
17.07.2019

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing

Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)Test report: 19-001962-PR02 PB-
A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check


www.ift-rosenheim.de/ift-geprueft
ID: 599-EF0D5