

Number	16-004348-PR01 (NW-A01-02-en-01)
Owner	Metaloumin SA 20 Aghiou Fanouriou Str. 136 71 Acharnes - Athens Greece
Product	Double tilt and turn balcony door with opening meeting stile
Designation	Shipping name: Energy 22
Details	Manufacturer Metaloumin SA, - Acharnes - Athens; Material Aluminium system with thermal break; Type of opening Turn / tilt and turn; Opening direction Active sash DIN right (opening) to the inside, Inactive sash DIN left (opening) to the inside; Overall dimensions (W x H) 1,400 mm x 2,200 mm
Special features	Locking situation. Test sequence.

Result

Air permeability according to EN 12207:2016-12



Class: 3

Resistance to wind load according to EN 12210:2016-03



Class: C3/B3

Watertightness according to EN 12208:1999-11



Class: 3A

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 16-004348-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
16.03.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 188-BEC6A