

## Classification Report

Number	20-002523-PR02 (NW-A01-02-en-01)
Owner	Metaloumin SA 20 Aghiou Fanouriou Str. 136 71 Acharnes - Athens Greece
Product	Double tilt and turn casement door with central opening meeting stile
Designation	System: Metaloumin Energy 24 Shipping name: OPENING-ENERGY 24
Details	Manufacturer Metaloumin SA, - Acharnes - Athens; Material Aluminium system with thermal break; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to the inside, Inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 1400 mm x 2200 mm
Special features	Test sequence. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

### Result \*\*)

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: C4/B4**

Watertightness according to EN 12208:1999-11



**Class: 5A**

\*\*) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim  
10.02.2022



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09  
) and corresponding national versions  
(e.g. DIN EN)

Test report: 20-002523-PR02 PB-A01-02-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 6B8-3EF5E